



# INCERT CERTIFICATE

## C-027-1361/b



Issued 19-03-2023  
Expiry date 25-01-2028

Replaces C-027-1361/a  
Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: Bus interface module for JA-100 wireless components  
Trademark: JABLOTRON  
Type designation: JA-111R  
Hardware / Software: NI10312 / LR61723

Placed on the market under the name or trademark of:

Name of the manufacturer: Jablotron Alarms a.s.  
Address: Pod skalkou 4567 /33  
City: 46601 Jablonec nad Nisou  
Country: CZ

This certificate is granted to:

Name of the certificate holder: Jablotron Alarms a.s.  
Address: Pod skalkou 4567 /33  
City: 46601 Jablonec nad Nisou  
Country: CZ

Ron Scheepers  
Managing director

*This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.*

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



# CERTIFICATE

**Remarks and observations**

The following conditions are applicable:

Category: Interface

Security grade: 2

Environmental class: II

Equipment class: Fixed

Factory location:

Prosoyo Technology Limited

Tai Po Industrial Estate

Chang Ping, Dong Guan

China

Product inspection location:

Distri-Company

Steenweg Deinze 59

Nazareth

Belgium

**Documentation lodged for this INCERT certificate**

Test Reports:

- TESTALARM Praha, Ltd.: 2021 9938, 25 June 2021
- VZLU TEST, a.s.: P-VZLUTEST-017/17, 27 January 2017
- Cesky metrologicky institut: 8551-PT-E0167-18, 23 July 2018
- Cesky metrologicky institut: 8551-PT-E0083-21, 13 April 2021
- TESTALARM Praha, Ltd.: 2021 9930, 09 June 2021
- Telefication B.V.: 170600630-001-Ver 1.00, 07 December 2017

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

T 031+A1 February, 2018

**Applied Standards**

EN 50131-3	March, 2009
EN 50130-5	June, 2011
EN 50130-4+A1	October, 2014
EN 50131-5-3	March, 2017
EN 50131-1+A1+A2+A3	June, 2020

**The product as described in this certificate includes the following type designations**

- Product description: Bus interface module for JA-100 wireles components
- Trademark: JABLOTRON
- Type designation: JA-111R
- Hardware version: NI10312
- Software version: LR61723